

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
JONES 1	1/9/2024 05:19	1/19/2024 10:54	70284324001	Lead	1.6	5	ug/L
JONES 2	1/9/2024 05:20	1/19/2024 11:02	70284324002	Lead	<1.0	5	ug/L
JONES 5	1/9/2024 05:21	1/19/2024 11:06	70284324003	Lead	<1.0	5	ug/L
JONES 6	1/9/2024 05:22	1/19/2024 11:07	70284324004	Lead	<1.0	5	ug/L
JONES 8	1/9/2024 05:23	1/19/2024 11:09	70284324005	Lead	<1.0	5	ug/L
JONES 9	1/9/2024 05:24	1/19/2024 11:11	70284324006	Lead	<1.0	5	ug/L
JONES 14	1/9/2024 05:31	1/19/2024 11:12	70284324007	Lead	2.7	5	ug/L
JONES 15	1/9/2024 05:32	1/19/2024 11:14	70284324008	Lead	1.7	5	ug/L
JONES 17	1/9/2024 05:33	1/19/2024 11:18	70284324009	Lead	<1.0	5	ug/L
JONES 18	1/9/2024 05:34	1/19/2024 11:20	70284324010	Lead	1.2	5	ug/L
JONES 20	1/9/2024 05:35	1/19/2024 11:21	70284324011	Lead	1.6	5	ug/L
JONES 21	1/9/2024 05:36	1/19/2024 11:23	70284324012	Lead	<1.0	5	ug/L
JONES 23	1/9/2024 05:38	1/19/2024 11:24	70284324013	Lead	1.8	5	ug/L
JONES 24	1/9/2024 05:39	1/19/2024 11:26	70284324014	Lead	1.6	5	ug/L
JONES 26	1/9/2024 05:40	1/19/2024 11:27	70284324015	Lead	5.3	5	ug/L
JONES 27	1/9/2024 05:41	1/19/2024 11:29	70284324016	Lead	4.0	5	ug/L
JONES 29	1/9/2024 05:42	1/19/2024 11:30	70284324017	Lead	1.6	5	ug/L
JONES 30	1/9/2024 05:43	1/19/2024 11:32	70284324018	Lead	1.9	5	ug/L
JONES 32	1/9/2024 05:44	1/19/2024 11:36	70284324019	Lead	<1.0	5	ug/L
JONES 33	1/9/2024 05:45	1/19/2024 11:38	70284324020	Lead	<1.0	5	ug/L
JONES 35	1/9/2024 05:46	1/19/2024 11:42	70284324021	Lead	<1.0	5	ug/L
JONES 36	1/9/2024 05:47	1/19/2024 11:47	70284324022	Lead	1.7	5	ug/L
JONES 38	1/9/2024 05:48	1/19/2024 11:54	70284324023	Lead	1.1	5	ug/L
JONES 39	1/9/2024 05:49	1/19/2024 11:56	70284324024	Lead	1.8	5	ug/L
JONES 41	1/9/2024 05:27	1/19/2024 11:57	70284324025	Lead	<1.0	5	ug/L
JONES 42	1/9/2024 05:28	1/19/2024 11:59	70284324026	Lead	2.4	5	ug/L
JONES 43A	1/9/2024 05:29	1/19/2024 12:00	70284324027	Lead	2.1	5	ug/L
JONES 43B	1/9/2024 05:30	1/19/2024 12:02	70284324028	Lead	3.6	5	ug/L
JONES 46	1/9/2024 05:09	1/19/2024 12:03	70284324029	Lead	1.3	5	ug/L
JONES 47	1/9/2024 05:05	1/19/2024 12:05	70284324030	Lead	2.0	5	ug/L
JONES 48	1/9/2024 05:06	1/19/2024 12:06	70284324031	Lead	<1.0	5	ug/L
JONES 50 DF HALL	1/9/2024 05:13	1/19/2024 12:08	70284324032	Lead	<1.0	5	ug/L
JONES 57	1/9/2024 05:17	1/19/2024 12:12	70284324033	Lead	<1.0	5	ug/L
JONES 58	1/9/2024 05:18	1/19/2024 12:14	70284324034	Lead	<1.0	5	ug/L
JONES 59	1/9/2024 05:19	1/19/2024 12:15	70284324035	Lead	<1.0	5	ug/L
JONES 60A	1/9/2024 05:57	1/19/2024 12:17	70284324036	Lead	2.5	5	ug/L
JONES 60B	1/9/2024 05:58	1/19/2024 12:18	70284324037	Lead	<1.0	5	ug/L
JONES 61	1/9/2024 05:55	1/19/2024 12:20	70284324038	Lead	2.0	5	ug/L
JONES 62	1/9/2024 05:56	1/19/2024 12:21	70284324039	Lead	1.4	5	ug/L
JONES 64A	1/9/2024 06:16	1/19/2024 12:23	70284324040	Lead	2.5	5	ug/L
JONES 64B	1/9/2024 06:17	1/19/2024 12:30	70284324041	Lead	2.1	5	ug/L
JONES 67	1/9/2024 06:14	1/19/2024 12:35	70284324042	Lead	4.6	5	ug/L
JONES 68	1/9/2024 06:15	1/19/2024 12:39	70284324043	Lead	<1.0	5	ug/L
JONES 70	1/9/2024 06:12	1/19/2024 12:41	70284324044	Lead	5.7	5	ug/L
JONES 71	1/9/2024 06:13	1/19/2024 12:42	70284324045	Lead	<1.0	5	ug/L
JONES 73	1/9/2024 06:10	1/19/2024 12:44	70284324046	Lead	3.2	5	ug/L
JONES 74	1/9/2024 06:11	1/19/2024 12:48	70284324047	Lead	1.5	5	ug/L
JONES 75	1/9/2024 06:07	1/19/2024 12:50	70284324048	Lead	3.9	5	ug/L
JONES 76	1/9/2024 06:08	1/19/2024 12:51	70284324049	Lead	1.7	5	ug/L
JONES 78	1/9/2024 06:05	1/19/2024 12:53	70284324050	Lead	1.8	5	ug/L
JONES 79	1/9/2024 06:04	1/19/2024 12:54	70284324051	Lead	1.4	5	ug/L
JONES 81	1/9/2024 06:01	1/19/2024 12:56	70284324052	Lead	2.8	5	ug/L
JONES 82	1/9/2024 06:02	1/19/2024 12:57	70284324053	Lead	<1.0	5	ug/L
JONES 84A	1/9/2024 06:00	1/19/2024 12:59	70284324054	Lead	1.8	5	ug/L
JONES 87	1/9/2024 05:53	1/19/2024 13:00	70284324055	Lead	1.9	5	ug/L
JONES 88	1/9/2024 05:54	1/19/2024 13:02	70284324056	Lead	<1.0	5	ug/L

Room 136	Classroom Sink	Posted sign
----------	----------------	-------------

Room 234	Classroom Sink	Posted Sign
----------	----------------	-------------

NYSDOH Action Level for Lead In Schools of 5 ppb